




Data Driven Wind Power Integration
Yesterday -Today-Tomorrow
Carnegie Mellon University
March 13, 2012

Paul McGlynn
Director, System Planning
PJM

- 26% of generation in Eastern Interconnection
- 28% of load in Eastern Interconnection
- 19% of transmission assets in Eastern Interconnection




KEY STATISTICS


PJM member companies	750+
millions of people served	60
peak load in megawatts	163,848
MWs of generating capacity	185,600
miles of transmission lines	65,441
GWh of annual energy generation	832,331
sources	1,365
square miles of territory	214,000
area served	13 states + DC
Internal/external tie lines	142

**21% of U.S. GDP
produced in PJM**

As of 1/4/2012



Fuel Mix of All Queued Generation – Tomorrow?





Wind

20%
 12,884,632 MWh - 2011
 36,437,679 MWh - cumulative



Hydro

1%
 8,590,500 MWh - 2011
 53,816,616 MWh - cumulative



Other Gas

50%
 771,604 MWh - 2011
 4,017,208 MWh - cumulative



Solar

139%
 647,061 MWh - 2011
 1,001,975 MWh - cumulative



Captured Methane

-5%
 3,180,791 MWh - 2011
 17,613,343 MWh - cumulative



Wood Waste

-13%
 3,064,151 MWh - 2011
 22,211,009 MWh - cumulative



Pumped Storage

-12%
 6,469,359 MWh - 2011
 45,221,259 MWh - cumulative





Solid Waste

-2%
 4,066,359 MWh - 2011
 29,436,495 MWh - cumulative

This slide shows how many megawatt-hours of renewable energy were produced in 2011 and cumulatively since tracking began in 2005. It also shows the percent change between 2010 and 2011.

Increasing Wind Penetration in PJM







Projected Renewable Energy Requirements in PJM

By 2026: 135,000 GWh of renewable energy, 14% of PJM annual net energy
(**42 GW** of wind and **11 GW** of solar)

Wind and **Solar** Requirements in PJM (MW)



January Integrated Hourly Wind Generation (MW)




Relying on information from wind resources, PJM forecasts wind conditions. The goal of this forecasting effort is to:

- 1) Augment real-time reliability decisions by PJM operators
- 2) Accurately schedule generation in the Day-Ahead and Reliability Analysis unit commitment



Met Mast







- Wind is coming, but not on the peak hours (13% available at the time of peak)
- Energy Storage is needed to ensure renewables achieve their potential

PJM Load and Wind Resources

PJM Load and Total Wind



Grid-Scale Energy Storage System – 32 MW Battery



Laurel Mountain

Wind Farm

98 MW


61 turbines


Battery Storage

Lithium-ion (A123)

Power 32 MW, Energy 8 MWh

105-gallon electric water heater demonstrates minimization of cost while responding to the PJM wholesale price signal and the PJM frequency regulation signal.






Effects on Reserve Requirement:

Higher wind generation mean higher variability and faster Rates of Change of Frequency

To mitigate these effects, Grid requires Higher amounts of reserves as well as faster responding reserves

- PJM Frequency Regulation Signal
- Water heater power consumption +/- 2.25 Kw base point



PHEV: Benefits to Markets

Its really going to happen this time.



Fuel	
Premium	309 ⁹
Regular	299 ⁹
Electric	75 ⁹

Battery Electric Vehicles

- 2010 Coda Automotive Sedan
- 2010 Mitsubishi iMiEV BEV
- 2010 Nissan LEAF
- 2010 Ford Battery Electric Van
- 2010 Tesla Roadster Sport EV
- 2011 Peugeot Urban EV*
- 2011 Renault Kangoo Z.E.
- 2011 Renault Fluence Z.E.
- 2011 Tesla Model S
- 2011 BYD e6 Electric Vehicle
- 2011 Ford Battery Electric Small Car
- 2011 Opel Ampera Extended Range BEV*
- 2012 Fiat 500 minicar



1902 Lohner-Porsche PHEV



2009 BWM MINI E

Battery Electric Vehicles

- 2012 Renault City Car*
- 2012 Renault Urban EV*
- 2012 Audi e-tron
- 2013 Volkswagen E-Up*
- 2016 Tesla EV

Extended Range Electric Vehicles

- 2010 Chevy Volt Extended Range

Plug-in Hybrid Vehicles

- Fisker Karma S Plug-in Hybrid
- 2010 Toyota Plug-in Hybrid
- 2011 BYD F3DM Plug-in Hybrid
- 2012 Bright Automotive IDEA Plug-in Hybrid
- 2012 Ford Plug-in Hybrid
- 2012 Volvo Plug-in Hybrid



3/31/2010

Pony Under the Christmas Tree?

60¢ (PJM Off-peak Price)
~~75¢ per "Gallon"~~
^




Load in GW




50mSec Charge/Discharge


Hour of Day










Operational Performance – Aggregation of 16 water pumps:










**Phasor data
measures system
dynamic behavior
during disturbances
that simulations
can't yet accurately
predict**



Measurements give us current system states:

For true situation awareness we need to know;

- **Where the edge is**
- **How close to the edge we can safely (reliably) operate**

Baselining studies of phasor angles are required for understanding system behavior

- For more information about PJM's initiatives:
 - Exploring Tomorrow's Grid: New developments and technologies to advance the grid:
<http://www.pjm.com/about-pjm/exploring-tomorrows-grid/smart-grid.aspx>
 - Renewables Dashboard: See how PJM is working to bring renewable energy to the grid:
<http://www.pjm.com/about-pjm/newsroom/renewable-dashboard.aspx>