


# **Clearing the Fog of Assumptions**

Dynamic Line Ratings Provides Real Time  
Visibility and Market Efficiency

- Project Description and Scope
- Economic Cost of Thermally Constrained Lines
- Comparison of Static Limits to Dynamic Limits
- Integration of Dynamic Line Ratings into Economic Dispatch
- Results from Deployment in Texas
- Expansion of DLR into additional areas

# Oncor System Attributes




## Oncor System Attributes

- 180 congested lines
- 30 lines responsible for 80% of congestion
- \$172m average annual Oncor congestion

# Problem and Opportunity


## Oncor System Congestion



- Situation: Overhead thermal lines responsible for significant congestion costs
- Obstacle: Static assumptions force operators to use artificially low limits
- Next Generation SCADA Hypothesis:  
Real time line information can significantly reduce congestion costs


# Oncor SGDP Project Scope

- 8 Lines (138kV-345kV)
- Installation 2010-2011
- ERCOT Go-Live 5/2012



IEEE 738

$$\Delta T = I^2 R + Q_s - Q_r - Q_c$$



Assumed


$$I_{\max}^2 R = T_{\max} - Q_s + Q_r + Q_c$$



IEEE 738

$$\Delta T = I^2R + Q_s - Q_r - Q_c$$

$$I_{\max}^2 R = T_{\max} - \underbrace{Q_s + Q_r}_{\text{Measured}} + \underbrace{Q_c}_{\text{Assumed}}$$




IEEE 738

$$\Delta T = I^2 R + Q_s - Q_r - Q_c$$

$$Q_c = I_{\text{meas}}^2 R - Q_s + Q_r - \Delta T_{\text{calc}}$$

$$I_{\text{max}}^2 R = T_{\text{max}} - \underbrace{Q_s + Q_r}_{\text{Measured}} + \underbrace{Q_c}_{\text{Calculated}}$$







Parameters	Static Ratings	Ambient Adjusted Ratings	Dynamic Ratings
Solar and Ambient Conditions	Assumed	Measured (regional)	Measured (corridor specific)
Wind Speed	Assumed	Assumed	Calculated
Tension	Assumed	Assumed	Measured
Sag or Clearance	Assumed	Assumed	Calculated
<b>Maximum Rating</b>	<b>Artificially limited to worst case scenario</b>	<b>Does not take into account wind (greatest cooling factor)</b>	<b>Calculated based on measured conditions</b>




## Weather-Based Cooling Distribution 1/5/2010



# Nexans Integrated Dynamic Line Rating Systems




## Adjustment Period & Real-Time Operations



# Capacity Increases from DLR


## Dynamic Line Rating (DLR) And Ambient Adjusted Rating (AAR)

Rogers Hill-Elm Mott, September, 2011  
Daily Distribution




# Savings in Day-Ahead Market

## Congestion Cost Per Hour 11/1/11 DAM



# Savings in SCED (5-min Dispatch)

## Extrapolated Congestion Cost Per Hour 11/1/11 SCED






Congestion Reduction Projections			
		Direct Line	Peripheral Lines
Peak Day	Control	-	-
	Plus 5%	68%	54%
	Plus 10%	78%	100%
Annual	Control	-	-
	Plus 5%	60%	56%
	Plus 10%	100%	58%

- Control: dispatch with selected (direct) lines rated at static capacity
- Plus 5%/10%: dispatch with selected lines at “dynamic” capacity
- Peripheral Lines: any line sharing a substation with a direct line
- Percentage Reduction: change in congestion cost attributable to line(s)
- Peak Day: 7/27/2011
- Annual: interpolation based on 12 sample days throughout the year

# Indicative Oncor DLR Value and ROI

## Value Analysis for DLR in Oncor



If DLR installed on 30 of Oncor's likely congested lines:

- NPV Cost (Installation): €12.0m
- NPV Savings (Congestion over 5 years): €68.0m
- ROI: 467%
- Payback: 9.6 Months


# Second Deployment After SGDP Success

## Projects to Address 2012 West Texas Congestion

Constraint	2012 Congestion Rent	Projects	Expected Congestion Relief
Odessa North 138/69 kV autotransformer	\$132,736,881	Odessa North 138/69 kV autotransformer with a larger capacity transformer (87 MVA to 125 MVA emergency rating)	Nov-12
China Grove-Bluff Creek Switch 138 kV line	\$54,362,222	New WETT and Oncor Faraday/ Willow Valley 345/ 138 kV autotransformer will connect CREZ 345 kV facilities to the 138 kV	Jun-13
Odessa-Odessa North 138 kV line	\$17,531,349	Reconductor the Odessa-Odessa North 138 kV line	Dec-13
Odessa North-Odessa Basin Switch 69 kV line	\$7,264,839	New Odessa North-Goldsmith Junction-Holt 138/69 kV double circuit	May-14
Midland East-Windwood 138 kV line	\$4,820,128	ERCOT and Oncor are continuing to study the long-term solution	TBD

### Short-term Improvements:

- Oncor will create a new temporary 138 kV circuit between Moss and Holt via Goldsmith Junction by June 2013
- The temporary circuit will lessen the loading on the Odessa North circuits but will not completely relieve the congestion
- Oncor will install dynamic line rating equipment on the Odessa-Odessa North 138 kV line to lessen congestion by summer 2013
- Oncor will install dynamic line rating equipment on the Midland East-Windwood 138 kV line by summer 2013



- Connection: Sensor to Next-Generation SCADA
  - Incorporation of real time, individual line capacity data into SCED
  - First stages of grid operations that rapidly adapt to changing conditions
  - Framework for future, high-definition closed-loop systems
- Connection: Concept to SGDP to Business Case
  - Theory: dynamic line ratings can provide customer savings
  - Results: significant efficiencies from reduced congestion costs
  - Practice: sufficient evidence to justify full commercial deployments

# **Integrated Dynamic Line Rating Systems**



[eric.hsieh@nexans.com](mailto:eric.hsieh@nexans.com)

Eric Hsieh