

Grid Monitoring Using Phasor Measurement Units Chuck Wells



- Analysis of Blackout data from 14 August, 2003
- Analysis of Blackout data from 23 September, 2003
- Analysis of Blackout data from June 15, 2005
- Zaborszky-Ilic textbook



Oscillations before Blackout




Fig. 12. Spectral history of AEP Kanawha River bus frequency for August 14 Blackout. 12:00-16:10 EDT

OSIsoft.

Oscillations before Blackout





Fig. 13. Spectral history of Ameren Rush Island bus frequency for August 14 Blackout. 12:00-16:10 EDT

Oscillations in Sweden






5




Oscillations before blackout June 15, 2005






First event, power factor reversal






Zoomed in view






Power factor reversal






Power flow reversal



Increase in reactive power flows






11




Frequency swell, Gosling high




First grid oscillation






OSIsoft.

Waterfall chart of first oscillation




Waterfall rotation








Gosling relative phase angles





Second oscillation in grid






Decrease in damping

1 PI ProcessBook - [LongTerm Voltage and Frequency]	
He Edit View Insert Iools Draw Arrange Window Help	_ - - - ×
▋D ◙ █ ◙ D, % ◙ ® ♀♀♀↓ № ₩ 8 ਞ ਞ ᠌ ◙ 100% Ӯ ӣ № ҟ ៷ \ \ □ т о Ҁ ▫▫ □ Ҡ ҂ ҄ҧ ⊾ 終 ≫ ■ छ छ ⋬ ▶ ⊻	
] a = छ छ छ ● M × 🗗 🗔 ७ %ू र 🛛 😵 🛤 💶 💽 🔲	
Coslin Frequency 060/019 060/018	
90.5	ENT_OSUN-MTRO: ARBF
	80.020 Hz
80.2	
593	
597	
596	
53.5 6/15/2005 7:56:09 PM B/15/2005 7:56:21.75919 B/15/2005 7:56:25 08548 PM 6/15/2005 7:56:42 PM	
Osacin - Hitro Depansy	
Ready Server Time 🕅	


Collapse: 6:56 pm









• Wave front propagation speed









〃 \$ • 🚄 🌾 🔪 ଓ 🗆 ◯ ◯ 🔛 🖄 • 🚄 • 📥 • ≡ 🚍

777 Davis Street







泡 💿 🗔




200




200



to initial time range settings



200




12 🔷 🗔





Voltage								
285			And the second	Manual tableting a second	Watter and the second of	**************************************	nipî (d	 Gap004.AVoltage 280.53 Volts
200 Milliopethikingethere Millionethikingethere 275	nin and and a state of the	an a	and and a second se Second second	and the second secon		la angla sa	Her in	 ○ Gap004.BVoltage 283.44 Volts
270								282.21
265								Volts
260								
255								
250								
245								
240 10/8/2005 3:1	19:53 PM	8.0	3 hours		10/8/2	005 11:21:40 PM		

<u>-</u> ile ț	<u>E</u> dit	⊻iew <u>I</u>	nsert	<u>T</u> ools <u>D</u>)raw <u>A</u>	<u>\</u> rrange	<u>W</u> indow	Help																		_
		<i>a</i> [b 3	6 🖻 🛙	a 4	2 ± 🗠	± 💊	etta 🗧	8	ţ	Ъ,	1	100%	- -	▶?		2	•								
\equiv	5	6	i 🤆	M	× 🖻)]]]]	† <u>+</u>	8	12:00	•			k >>		□т	\circ (12.3	3 🗆	∿ ⊿	^Ն հո	<u>*</u>	× !	🛛 🗐	🔀 🧃	🧟 🤇











A 🔾 💽








Phasor display approaches

DHS (II)
DHS (I)

Overall system architecture







- Time synchronized measurements
- 110 measurements from each PMU
 - Power, Volts, Current, Frequency, Phase,
- Meets IEEE 1344 Syncrophasor standard
- Meets proposed IEEE C37.118 standard
- Accuracy .01 deg, 1 mHz, 0.025 % V,I
- Manufactured by Aribiter Systems



- Real time spectral analysis
 - All critical modes identified, tracked, and alarmed
- Real time synchronized differences
 - Angle, phasor, frequency, voltage, power, current
- Phasor "tool box"
- Synchronized pseudoACE calculations
- Frequency coherence calculations
- Real time Dynamic ampacity calculations